



NOTE:

1. Kor-n-seal manhole or equal considered acceptable alternate.
2. All dog houses shall be grouted on inside and outside.
3. When the manhole structure is constructed outside the traveled roadway a witness post and sign (MH) shall be installed next to the manhole.
4. Minimum of 2-2" adjusting rings, maximum of 3 adjusting rings or a total of 8" of stack height for new construction.
5. No steps shall be installed in manholes.



**CITY OF
CHANHASSEN**

STANDARD
SANITARY
MANHOLE

REVISED: 11-19

FILE NAME: G:\ENG\SPCS\2101

ENGINEERING DEPARTMENT

PLATE NO.:

2101