




DEPRESSED CORNER




FAN




PERPENDICULAR



DIAGONAL



TIERED PERPENDICULAR



SECTION B-B
PARALLEL/DEPRESSED CORNER

- NOTES:
- SEE STANDARD PLATE 7038 AND SHEET 4 OF 5 FOR DETAILS ON DETECTABLE WARNING.
 - SLOPES ARE DEFINED AS ABSOLUTE ELEVATION DIFFERENCE PER LENGTH OF RUN. (AS OPPOSED TO A RELATIVE SLOPE WITH RESPECT TO A CURB LINE OR CURB HEIGHT.)
 - LANDINGS SHALL BE LOCATED ANYWHERE THE PEDESTRIAN ACCESS ROUTE CHANGES DIRECTION, AND AT THE TOP OF RAMP THAT HAVE RUNNING SLOPES GREATER THAN 5%.
 - INITIAL CURB RAMP LANDINGS SHALL BE CONSTRUCTED WITHIN 15" FROM THE BACK OF CURB, WITH 6" FROM THE BACK OF CURB BEING THE PREFERRED DISTANCE.
 - SECONDARY CURB RAMP LANDINGS ARE REQUIRED FOR EVERY 30' OF VERTICAL RISE WHEN THE LONGITUDINAL SLOPE IS 5% OR GREATER.
 - CONTRACTION JOINTS SHALL BE CONSTRUCTED AT ALL GRADE BREAKS.
 - TOP OF CURB SHALL MATCH PROPOSED ADJACENT WALK GRADE.
 - USE 6" CONCRETE FOR ALL INITIAL RAMP AND LANDING AREAS.
 - CONTRACTOR SHALL EMPLOY APPROPRIATE METHODS FOR INTERMEDIATE GRADE CONTROL TO ENSURE ALL GRADE BREAKS ARE CONSTRUCTED PROPERLY.
 - ALL GRADE BREAKS SHALL BE PERPENDICULAR TO THE DIRECTION OF TRAVEL/PEDESTRIAN ACCESS ROUTE.
 - MINIMUM WIDTH OF DETECTABLE WARNING IS REQUIRED FOR ALL RAMPS. SHARED USE PATHS SHALL HAVE DETECTABLE WARNING ACROSS THE ENTIRE WIDTH OF PATH WHEN THE PATH CROSSES A ROAD.
 - 0' CURB HEIGHT.
 - FULL CURB HEIGHT.
 - LESS THAN 5% PREFERRED, 5-8.3% SHOULD ONLY BE USED AFTER ALL OTHER SLOPES HAVE BEEN CONSIDERED AND DEEMED IMPRACTICAL.
 - 1/2" PREFORMED JOINT FILLER MATERIAL AKASITO JM 213. JOINT FILLER SHALL BE PLACED BETWEEN RAMP AND LANDING. DETECTABLE WARNING SHALL BE SET BACK 3" FROM THE BACK OF CURB. RADIAL DETECTABLE WARNING SHALL BE SET BACK 3"-6" FROM THE BACK OF CURB.
 - SEE PEDESTRIAN ACCESS ROUTE, CURB AND GUTTER DETAIL FOR INFORMATION ON CONSTRUCTING CURB AND GUTTER AT CURB OPENINGS. SEE SHEET NO. 3 OF 5.
 - 4' BY 4' MIN. LANDING WITH MAX. 2% SLOPE IN ALL DIRECTIONS.
 - IF RUNNING SLOPE IS LESS THAN 5.0% NO SECONDARY LANDING IS REQUIRED.
 - V CURB, IF USED, SHALL BE PLACED OUTSIDE THE SIDEWALK LIMITS WHEN RIGHT OF WAY ALLOWS. SEE SHEET 5 OF 5.
 - DETECTABLE WARNINGS MAY BE PART OF 4' X 4' LANDING AREA IF IT IS NOT FEASIBLE TO CONSTRUCT THE LANDING OUTSIDE OF THE DETECTABLE WARNING AREA.
 - SEE SHEET 4 OF 5, TYPICAL SIDE TREATMENT OPTIONS, FOR DETAILS ON FLARES AND RETURNED CURBS.
 - SEE SHEET 3 OF 5 FOR FURTHER DETAIL.
 - DIAGONAL RAMPS SHOULD ONLY BE USED AFTER ALL OTHER CURB RAMP TYPES HAVE BEEN CONSIDERED AND DEEMED IMPRACTICAL.

MnDOT STANDARD PLAN SHEET
NO. 5-297.250 (1 OF 5)



**CITY OF
CHANHASSEN**

Pedestrian Curb Ramps
Page 1 of 5

REVISED: 10-16
FILE NAME: G:\ENG\SPECS\5215

ENGINEERING DEPARTMENT

PLATE NO.: 5215