




CONCRETE WALK EDGES ADJACENT TO CONCRETE STRUCTURES



RAILROAD CROSSING PLAN VIEW




V CURB INTERSECTION




V CURB ADJACENT TO BUILDING


CONCRETE CURB DESIGN V	
CURB HEIGHT H	6"
CURB WIDTH W	4"
H	< 6"
	≥ 6"



V CURB ADJACENT TO LANDSCAPE CURB WITHIN SIDEWALK LIMITS



V CURB ADJACENT TO LANDSCAPE CURB OUTSIDE SIDEWALK LIMITS



DETECTABLE EDGE AT QUADRANT ⑤

- NOTES:
- ALL V-CURB CONTRACTION JOINTS SHALL MATCH CONCRETE WALK JOINTS.
 - V CURB SHALL BE PLACED OUTSIDE THE SIDEWALK LIMITS WHEN RIGHT OF WAY ALLOWS.
 - V CURB NEXT TO BUILDING SHALL BE A 4" WIDTH AND SHALL MATCH PREVIOUS TOP OF SIDEWALK ELEVATIONS.
 - END TAPERS AT TRANSITION SECTION SHALL MATCH INPLACE SIDEWALK GRADES.
 - ALL V CURB SHALL MATCH BOTTOM OF ADJACENT WALK.
 - EDGE BETWEEN NEW V CURB AND INPLACE STRUCTURE SHALL BE SEALED AND BOND BREAKER SHALL BE USED BETWEEN EXISTING STRUCTURE AND PLACED V-CURB.
 - EDGE OF DETECTABLE WARNING SURFACES SHALL BE PLACED 6" MINIMUM TO 15" MAXIMUM FROM THE CENTERLINE OF THE NEAREST RAIL WHEN PEDESTRIAN GATES ARE PROVIDED. DETECTABLE WARNING SURFACES SHALL BE PLACED ON THE SIDE OF THE GATES OPPOSITE THE RAIL.
 - ALL CONSTRUCTED CURBS MUST HAVE A CONTINUOUS DETECTABLE EDGE FOR THE VISUALLY IMPAIRED. THIS DETECTABLE EDGE REQUIRES TRUNCATED DOMES WHEREVER THERE IS ZERO-INCH HIGH CURB. CURB TRANSITIONS ARE CONSIDERED A DETECTABLE EDGE WHEN THE TAPER STARTS IMMEDIATELY AT THE EDGE OF THE TRUNCATED DOMES AND UNIFORMLY RISES TO A 3-INCH MINIMUM CURB HEIGHT. ANY CURB NOT PART OF A CURB TRANSITION AND LESS THAN 3 INCHES IN HEIGHT IS NOT CONSIDERED A DETECTABLE EDGE AND THEREFORE IS NOT COMPLIANT WITH ACCESSIBILITY GUIDELINES.

MNDOT STANDARD PLAN SHEET NO. 5-297.250 (5 OF 5)



CITY OF CHANHASSEN

Pedestrian Curb Ramps

Page 5 of 5

REVISED: 10-16

FILE NAME: G:\ENG\SPECS\5215D

ENGINEERING DEPARTMENT

PLATE NO.:

5215D