



Thrust blocking may be a Mega lug cap or plug W/Blue Core bolts. Tie back to the previous joint is required.

After meeting the test requirements the air bleed line (if installed) shall be disconnected at the plug with no additional compensation.

Note:

A water service tap or nearby hydrant may be used to bleed air out of the line, if approved by the engineer.



**CITY OF  
CHANHASSEN**

AIR  
BLEED  
DETAIL

REVISED: 11-16

FILE NAME: G:\ENG\SPECS\1003

ENGINEERING DEPARTMENT

PLATE NO.:

1003