



NOTES:

1. Do not plug end of curb stop.
2. Add 6" crimped pigtail to curb stop.
3. The service line between the main shutoff corp. and curb box shall be one continuous seamless piece of pipe, couplers will not be permitted
4. Corporation cock to be of the quick compression type as stated in section 2.11 of the watermain specifications.
5. All taps require use of stainless steel saddles on all mains.
6. Saddles shall be Smith Blair 371-372 or approved equal as per section 2.14 of the watermain specifications.
7. Install Tracer Wire System as per Detail Plate 5505.



**CITY OF
CHANHASSEN**

TYPICAL
WATER
SERVICE

REVISED: 12-19

FILE NAME: G:\ENG\SPECS\1005

ENGINEERING DEPARTMENT

PLATE NO.: 1005